

CONSIGNES D'INTERVENTION

022.0004

A
C
C
E
S

A DEPARTEMENTAL 149 BIS CLISSON MORTAGNE

R
I
S
Q
U
E
S

– RISQUE D'EXPLOSION

B CUVE FUEL ENTERREE 40M3

F STOCKAGE EN SAC 500T

C 22 SILOS A BLE 1047M3

G LOCAL SURPRESSEUR

D 4 SILOS ISSUS 410 M3

E 43 SILOS FARINES 283M3

M
O
Y
E
N
S

 PI N° 800 PARKING DEVANT LA MINOTERIE
PRESSION= 2.3B DEBIT =102 M/H₃

 PENNA N° 900

 CENTRALE ALARME SSI INTERIEUR SALLE DE COMMANDE MOULIN(1ER ETAGE)

 COLONNE SECHE (RDC AU NIVEAU 6)

 DESENFUMAGE NATUREL A COMMANDE MANUELLE

C
O
U
P
U
R
E
S

1  GENERALE ELECTRIQUE (TRANSFO) PAR E.R.D.F

2  GENERALE T.G.B.T (R.D.C)

3  PARTIELLE ELECTRIQUE (VOIR PLAN DES NIVEAUX)

A
U
T
R
E
S

H 2 SEPARATEUR D'HYDROCARBURE ET VANNE DE SECURITE